




APPROX. WEIGHT  
(LBS)  
73



FRONT VIEW  
(PANELS REMOVED)




SIDE VIEW  
(PANELS REMOVED)





BOTTOM VIEW

1/4-20 GROUND STUD



TOP VIEW  
(PANEL REMOVED)

SEE NOTE 1, 2, & 3



CUSTOMER CONNECTION  
DETAIL VIEW AT REACTOR

NOTES:

1. TERMINAL SCREW TIGHTENING TORQUE: 16 IN/LBS
2. WIRE RANGE: 4-14 AWG.
3. CUSTOMER DOES NOT CONNECT TO U4, V4, & W4 LOCATED ON THE REACTOR TERMINAL BLOCK.

THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU(EUROPEAN UNION) DIRECTIVE RoHS2		MATERIAL		CONFIDENTIAL AND PROPRIETARY INFORMATION THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION	
CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION				DESCRIPTION	
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES [MM] TOLERANCES ARE:  ANGLES: ± 1 °  1 PLACE .X: ± .1 [2.5]  2 PLACE .XX: ± .03 [0.76]  3 PLACE .XXX: ± .010 [0.254]		<b>MTE</b> POWER QUALITY. SOLVED.  N83 W13330 Leon Road Menomonee Falls, WI 53051 USA 800.455.4683 262.253.8200		MATRIX AP 8A 240V 60Hz FILTER, NEMA 3R ENCL	
		DRAWN KV	DATE 08/16/18	SIZE D	DWG No. CD MAPW0008A
		CHECKED WF	DATE 10/09/18	SCALE 1:3	REV 00
		APPROVED JG	DATE 10/10/18	SHEET 1 OF 1	