

APPROX. WEIGHT (LBS)
237


ECO No	DESCRIPTION	REV BY	DATE
M10031	UPDATED TITLE BLOCK AND DESCRIPTION	SL	02/06/17

D


C

B


A




FRONT VIEW
(PANELS REMOVED)




SIDE VIEW
(PANELS REMOVED)



BOTTOM VIEW




TOP VIEW
(PANELS REMOVED)





SEE NOTES 1 & 2

DETAIL A
CUSTOMER CONNECTION
DETAIL VIEW (THERMAL)



DETAIL B
(6 PLACES)



CUSTOMER CONNECTION
DETAIL VIEW

NOTES:

1. TERMINAL SCREW TIGHTENING TORQUE: 16 IN/LBS, MAX.
2. WIRE RANGE: 4-14 AWG.
3. CUSTOMER DOES NOT CONNECT TO U4, V4, & W4 ON REACTOR TERMINAL BLOCK.

THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU (EUROPEAN UNION) DIRECTIVE RoHS2		MATERIAL		CONFIDENTIAL AND PROPRIETARY INFORMATION THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION	
CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION				DESCRIPTION	
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES [MM] TOLERANCES ARE: ANGLES: ± 1 ° 1 PLACE .X: ± .1 [2.5] 2 PLACE .XX: ± .03 [0.76] 3 PLACE .XXX: ± .010 [0.254]		MTE POWER QUALITY. SOLVED. N83 W13330 Leon Road Menomonee Falls, WI 53051 USA 800.455.4683 262.253.8200		MATRIX AP 103A 380-415V 50HZ FILTER,NEMA 3R ENCL	
		DRAWN MM	DATE 06/03/13	SIZE D	DWG No. CD MAPW0103C
		CHECKED RH	DATE 06/08/17	REV 02	
		APPROVED RH	DATE 06/08/17	SCALE 1:4	SHEET 1 OF 1