


ECO No	DESCRIPTION	REV BY	DATE
M9952	REPLACED CAPPANEL-024 WITH CAPPANEL-024C	SL	01/31/17

- NOTES:
1. FILTER INCLUDES CAPPANEL-024C (QTY. 1)
  2. TERMINAL SCREW TIGHTENING TORQUE: 16 IN/LBS.
  3. WIRE RANGE: 4 - 14 AWG.
  4. REFER TO USER MANUAL FOR COMPLETE INSTALLATION INSTRUCTIONS.

THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU(EUROPEAN UNION) DIRECTIVE RoHS2		MATERIAL		CONFIDENTIAL AND PROPRIETARY INFORMATION THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION			
CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION				DESCRIPTION			
<div>UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES [MM] TOLERANCES ARE:</div> <div>ANGLES: ± 1 °</div> <div>1 PLACE .X: ± .1 [2.5]</div> <div>2 PLACE .XX: ± .03 [0.76]</div> <div>3 PLACE .XXX: ± .010 [0.254]</div> <div><div>N83 W13330 Leon Road Menomonee Falls, WI 53051 USA 800.455-4683 262.253-8200</div></div>		DRAWN		DATE		MATRIX SINGLE PH FILTER 90A, 480V, 60HZ	
		MN		03/26/15			
		CHECKED		DATE			
		JM		02/13/17			
		APPROVED		DATE		SIZE	
		JM		02/13/17		D	
						DWG No.	
						CD MSP0090D	
						REV	
						01	
						SCALE	
						1:3	
						SHEET 1 OF 1	