





APPROX. WEIGHT
(LBS)
82




FRONT VIEW
(PANELS REMOVED)




SIDE VIEW



BOTTOM VIEW



TOP VIEW
(PANELS REMOVED)



DETAIL A
CUSTOMER CONNECTION
DETAIL VIEW

NOTES:

1. TIGHTEN TERMINAL BLOCK SCREWS TO 16 IN/LBS. TORQUE.
2. TERMINAL WIRE SIZE: 4-14 AWG.

| | | | | | |
|--|--|---|--|--|-------------------------|
| THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU(EUROPEAN UNION) DIRECTIVE RoHS2 | | MATERIAL | | CONFIDENTIAL AND PROPRIETARY INFORMATION THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION | |
| CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION | | | | DESCRIPTION | |
| UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES [MM] TOLERANCES ARE: ANGLES: ± 1 ° 1 PLACE .X: ± .1 [2.5] 2 PLACE .XX: ± .03 [0.76] 3 PLACE .XXX: ± .010 [0.254] | | MTE POWER QUALITY. SOLVED. N83 W13330 Leon Road Menomonee Falls, WI 53051 USA 800.455.4683 262.253.8200 | | SWG 22A 600V 2-8kHz FILTER, NEMA 1/2 ENCL. | |
| DRAWN MN | | DATE 07/25/18 | | SIZE D | DWG No. CD SWGG0022E |
| CHECKED MN | | DATE 07/26/18 | | REV 00 | |
| APPROVED TL | | DATE 10/09/18 | | SCALE 1:4 | SHEET 1 OF 1 |