



APPROX. WEIGHT (LBS)
208


ECO No	DESCRIPTION	REV BY	DATE




FRONT VIEW (PANELS REMOVED)





SIDE VIEW




DETAIL A (6 PLACES)




DETAIL B CUSTOMER CONNECTION DETAIL VIEW (THERMAL)



BOTTOM VIEW



TOP VIEW (PANELS REMOVED)



CUSTOMER CONNECTION DETAIL VIEW

NOTES:

1. TERMINAL WIRE RANGE: 4-14 AWG.
2. TERMINAL SCREW TIGHTENING TORQUE: 16 INLBS.
3. REFER TO USER MANUAL FOR COMPLETE INSTALLATION INSTRUCTIONS

<p>THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU (EUROPEAN UNION) DIRECTIVE RoHS2</p> <p>CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION</p> <p>UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES [MM] TOLERANCES ARE:</p> <p>ANGLES: ± 1 °</p> <p>1 PLACE .X: ± .1 [2.5]</p> <p>2 PLACE .XX: ± .03 [0.76]</p> <p>3 PLACE .XXX: ± .010 [0.254]</p>		<p>MATERIAL</p>	<p>CONFIDENTIAL AND PROPRIETARY INFORMATION</p> <p>THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION</p>												
<p>MTE POWER QUALITY. SOLVED.</p> <p>N83 W13330 Leon Road Menomonee Falls, WI 53051 USA 800.455.4683 262.253.8200</p>		<table border="1"> <tr> <td>DRAWN</td> <td>DATE</td> </tr> <tr> <td>JD</td> <td>07/22/19</td> </tr> <tr> <td>CHECKED</td> <td>DATE</td> </tr> <tr> <td>CH</td> <td>11/11/19</td> </tr> <tr> <td>APPROVED</td> <td>DATE</td> </tr> <tr> <td>PY</td> <td>12/04/19</td> </tr> </table>	DRAWN	DATE	JD	07/22/19	CHECKED	DATE	CH	11/11/19	APPROVED	DATE	PY	12/04/19	<p>DESCRIPTION</p> <p>SWG 200A 208-240V 2-8kHz FILTER, NEMA 3R</p>
DRAWN	DATE														
JD	07/22/19														
CHECKED	DATE														
CH	11/11/19														
APPROVED	DATE														
PY	12/04/19														
<p>SIZE D</p> <p>SCALE 1:4</p>		<p>DWG No. CD SWGW0200A</p> <p>REV 00</p>	<p>SHEET 1 OF 1</p>												