



APPROX. WEIGHT
(LBS)
83


ECO No	DESCRIPTION	REV BY	DATE
M12090	REPLACE CMP W/CMB	MN	11/11/19




FRONT VIEW
(PANELS REMOVED)




SIDE VIEW




BOTTOM VIEW



TOP VIEW
(PANELS REMOVED)



SECTION A-A
CUSTOMER CONNECTION
DETAIL VIEW AT PANEL



DETAIL B
CUSTOMER CONNECTION
DETAIL VIEW

NOTES:

1. TERMINAL WIRE RANGE: 4-18 AWG.
2. TERMINAL WIRE RANGE: 4-14 AWG.
3. TERMINAL SCREW TIGHTENING TORQUE: 16 IN/LBS.
4. REFER TO USER MANUAL FOR COMPLETE INSTALLATION INSTRUCTIONS

THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU(EUROPEAN UNION) DIRECTIVE RoHS2		MATERIAL		CONFIDENTIAL AND PROPRIETARY INFORMATION THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION	
CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION				DESCRIPTION	
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES [MM] TOLERANCES ARE: ANGLES: ± 1 ° 1 PLACE .X: ± .1 [2.5] 2 PLACE .XX: ± .03 [0.76] 3 PLACE .XXX: ± .010 [0.254]		MTE POWER QUALITY. SOLVED. N83 W13330 Leon Road Menomonee Falls, WI 53051 USA 800.455-4683 262.253.8200		SINEWAVE NEXUS FILTER 12A 480V 60Hz NEMA 3R ENCL	
DRAWN MN		DATE 03/21/19		SIZE D	DWG No. CD SWNG0012D
CHECKED MN		DATE 11/11/19		REV 01	
APPROVED AK		DATE 11/22/19		SCALE 5:16	SHEET 1 OF 1