



APPROX. WEIGHT  
(LBS)  
85


ECO No	DESCRIPTION	REV BY	DATE
M10291	REPLACE CMP W/CMB-003	MN	11/13/19



FRONT VIEW  
(PANELS REMOVED)




SIDE VIEW




BOTTOM VIEW

Ø.41 [10.41] X .88 [22.35]  
SLOT, 4 PLACES


1/4-20 GROUND STUD



TOP VIEW  
(PANELS REMOVED)



SECTION A-A  
CUSTOMER CONNECTION  
DETAIL VIEW AT PANEL




DETAIL B  
CUSTOMER CONNECTION  
DETAIL VIEW

SEE NOTE 2

SEE NOTE 3

NOTES:

1. TERMINAL WIRE RANGE: 4-18 AWG.
2. TERMINAL WIRE RANGE: 4-14 AWG.
3. TERMINAL SCREW TIGHTENING TORQUE: 16 IN/LBS.
4. REFER TO USER MANUAL FOR COMPLETE INSTALLATION INSTRUCTIONS

THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU(EUROPEAN UNION) DIRECTIVE RoHS2		MATERIAL		CONFIDENTIAL AND PROPRIETARY INFORMATION THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION			
CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION				DESCRIPTION			
<div>UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES [MM] TOLERANCES ARE:</div> <div>ANGLES: ± 1 °</div> <div>1 PLACE .X: ± .1 [2.5]</div> <div>2 PLACE .XX: ± .03 [0.76]</div> <div>3 PLACE .XXX: ± .010 [0.254]</div>		<div><p><b>MTE</b> POWER QUALITY. SOLVED.</p></div> <div>N83 W13330 Leon Road Menomonee Falls, WI 53051 USA 800.455-4683 262.253.8200</div>		<div>SINEWAVE NEXUS FILTER 12A 600V 60Hz NEMA 1/2 ENCL</div>			
		DRAWN	DATE	SIZE	DWG No.	REV	
		MN	06/14/19	D		01	
		CHECKED	DATE				
		MN	11/13/19				
		APPROVED	DATE	SCALE			
		RH	11/25/19	5:16			SHEET 1 OF 1