

APPROX. WEIGHT
(LBS)
221

ECO No	DESCRIPTION	REV BY	DATE
M12075	CHANGE TO CAB-17, REPLACE CMP W/CMB, REPLACE CAPPANEL W/CAP	MN	11/07/19

D

C

B

A

FRONT VIEW
(PANELS REMOVED)

SIDE VIEW

DETAIL A
(3 PLACES)

SECTION D-D
CUSTOMER CONNECTION
DETAIL VIEW

DETAIL B
CUSTOMER CONNECTION
DETAIL VIEW (THERMAL)

DETAIL C
(3 PLACES)

TOP VIEW
(PANELS REMOVED)

BOTTOM VIEW

CUSTOMER CONNECTION
DETAIL VIEW

NOTES:

1. TERMINAL WIRE RANGE: 4-18 AWG.
2. TERMINAL SCREW TIGHTENING TORQUE: 16 IN/LBS.
3. REFER TO USER MANUAL FOR COMPLETE INSTALLATION INSTRUCTIONS

THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU(EUROPEAN UNION) DIRECTIVE RoHS2		MATERIAL		CONFIDENTIAL AND PROPRIETARY INFORMATION THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION	
CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION				DESCRIPTION	
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES [MM] TOLERANCES ARE: ANGLES: $\pm 1^\circ$ 1 PLACE .X: $\pm .1$ [2.5] 2 PLACE .XX: $\pm .03$ [0.76] 3 PLACE .XXX: $\pm .010$ [0.254]		MTE POWER QUALITY. SOLVED. N83 W13330 Leon Road Menomonee Falls, WI 53051 USA 800.455-4683 262.253.8200		SINEWAVE NEXUS FILTER 110A 480V 60Hz NEMA 1/2 ENCL	
		DRAWN MN	DATE 04/10/19	SIZE D	DWG No. CD SWNG0110D
		CHECKED MN	DATE 11/07/19		REV 01
		APPROVED RH	DATE 11/14/19	SCALE 1:4	SHEET 1 OF 1