

APPROX. WEIGHT  
(LBS)  
350

ECO No	DESCRIPTION	REV BY	DATE
M12092	REPLACE CMP W/CMB-006	MN	11/18/19

D

C

B

A

D

C

B

A

FRONT VIEW  
(PANELS REMOVED)

SIDE VIEW

BOTTOM VIEW

TOP VIEW  
(PANELS REMOVED)

DETAIL B  
CUSTOMER CONNECTION  
DETAIL VIEW (THERMAL)

SECTION C-C  
CUSTOMER CONNECTION  
DETAIL VIEW AT BOX

DETAIL D  
(3 PLACES)

CUSTOMER CONNECTION  
DETAIL VIEW

NOTES:

1. TERMINAL WIRE RANGE: 4-18 AWG.
2. TERMINAL SCREW TIGHTENING TORQUE: 16 IN/LBS.
3. REFER TO USER MANUAL FOR COMPLETE INSTALLATION INSTRUCTIONS

THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU(EUROPEAN UNION) DIRECTIVE RoHS2		MATERIAL		CONFIDENTIAL AND PROPRIETARY INFORMATION THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION	
CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION				DESCRIPTION	
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES [MM] TOLERANCES ARE:  ANGLES: ± 1 °  1 PLACE .X: ± .1 [2.5]  2 PLACE .XX: ± .03 [0.76]  3 PLACE .XXX: ± .010 [0.254]		<b>MTE</b> POWER QUALITY. SOLVED.  N83 W13330 Leon Road Menomonee Falls, WI 53051 USA 800.455-4683 262.253.8200		SINEWAVE NEXUS FILTER 130A 600V 60Hz NEMA 1/2 ENCL	
DRAWN MN		DATE 06/21/19		SIZE D	DWG No. CD SWNG0130E
CHECKED MN		DATE 11/18/19		SCALE 3:16	REV 01
APPROVED RH		DATE 11/25/19		SHEET 1 OF 1	