

APPROX. WEIGHT
(LBS)
110

ECO No	DESCRIPTION	REV BY	DATE
M12090	MOVE INTO CAB-T2, REPLACE CMP W/CMB	MN	11/11/19

D

C

B

A

D

C

B

A

FRONT VIEW
(PANELS REMOVED)

SIDE VIEW

TOP VIEW
(PANELS REMOVED)


BOTTOM VIEW

SECTION A-A
CUSTOMER CONNECTION
DETAIL VIEW AT PANEL

DETAIL B
CUSTOMER CONNECTION
DETAIL VIEW

NOTES:

1. TERMINAL WIRE RANGE: 4-18 AWG.
2. TERMINAL WIRE RANGE: 4-14 AWG.
3. TERMINAL SCREW TIGHTENING TORQUE: 16 IN/LBS.
4. REFER TO USER MANUAL FOR COMPLETE INSTALLATION INSTRUCTIONS

THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU(EUROPEAN UNION) DIRECTIVE RoHS2		MATERIAL		CONFIDENTIAL AND PROPRIETARY INFORMATION THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION							
CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION				DESCRIPTION							
<div>UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES [MM] TOLERANCES ARE:</div> <div>ANGLES: ± 1 °</div> <div>1 PLACE .X: ± .1 [2.5]</div> <div>2 PLACE .XX: ± .03 [0.76]</div> <div>3 PLACE .XXX: ± .010 [0.254]</div>		<div></div> <div>N83 W13330 Leon Road Menomonee Falls, WI 53051 USA 800.455-4683 262.253.8200</div>		<div>DRAWN</div> <div>MN</div> <div>DATE</div> <div>03/21/19</div>		<div>SINEWAVE NEXUS FILTER</div> <div>17A 480V 60Hz</div> <div>NEMA 3R ENCL</div>					
		<div>CHECKED</div> <div>MN</div> <div>DATE</div> <div>11/11/19</div>		SIZE					D	DWG No.	CD SWNW0017D
		<div>APPROVED</div> <div>AK</div> <div>DATE</div> <div>11/22/19</div>		SCALE		5:16		SHEET 1 OF 1			

